



Town of Surfside

REQUEST FOR PROPOSAL RFP NO. 2020-03

POINT LAKE CANAL SUBAQUEOUS WATER MAIN CROSSING TO BISCAYA ISLAND

Addendum No. 2

Date Issued: January 5, 2021

To All Proposers:

Proposers for the above-referenced RFP shall take note of the following changes, additions, deletions, clarifications or questions and answers to RFP No. 2020-03, which in accordance with the RFP Documents shall become a part of and have precedence over anything shown or described otherwise in the RFP.

THE FOLLOWING CHANGES ARE MADE TO THE RFP:

1. Bid item #2.01 specifies 8" DR11 HDPE for horizontal directional drilling. Can 8" DR18 Fusible PVC pipe be approved as an equal?

The Town will not accept material substitution at this time.

PROPOSER:

NAME: _____

TITLE: _____

DATE: _____