



TOWN OF SURFSIDE
Office of the Town Manager
MUNICIPAL BUILDING
9293 HARDING AVENUE
SURFSIDE, FLORIDA 33154-3009
Telephone (305) 861-4863

LETTER TO COMMISSION

No.: 249-2025

To: Mayor Charles W. Burkett, Vice Mayor Tina Paul, and
Members of the Town Commission

From: Mark Blumstein, Town Manager *MB*

Date: August 11, 2025

Subject: **Surfside Building Department – Plan Reviews Activity Report**

The purpose of this Letter to Commission (LTC) is to transmit the attached Plan Review Activity Report for the period August 4 to August 9, 2025.


This Report highlights the **86** total reviews performed by reviewer as follows:

- *Flood Review* by Erica Valdes – 1 review;
- *Building* by Manuel Salazar – 2 reviews;
- *Building/Structural* by Ulises Fernandez – 19 reviews;
- *Electrical* by Candelario Martinez – 21 reviews;
- *Mechanical* by Jan Perez – 9 reviews;
- *Planning/Zoning* by Scarlet Hammons – 12 reviews;
- *Plumbing* by Roberto Conde – 13 reviews;
- *Roofing* by Ulises Fernandez – 2 reviews;
- *Public Works* by Andre Eugent – 3 reviews; and
- *Structural/Multi-Family* by Chrome Engineering – 4 reviews.

I trust you will find this Report informative and insightful to better understand how our Town Building Department staff serves the Town and its residents and businesses.

If you have any questions or need additional information, feel free to contact me.

Enclosed: Surfside Building Department – Review Activity Report (August 4 – August 9, 2025)



ALL REVIEWS BY DUE DATE BY DEPARTMENT (08/04/2025 TO 08/09/2025) FOR TOWN OF SURFSIDE

Reviewer	Permit Number	Address	Submittal	Review	Review Status	Version	Required	Complete Date	Assigned Date	Due Date
BUILDING										
Erica Valdes	2025-007800-BR	1000 89Th St FI 33154	Building Review (Residential)	Flood	Requires Re-submit	1	Yes	07/17/2025	07/16/2025	08/06/2025

Comments: This permit is denied pending:

1-NPDES package signed and notarized by contractor (blank form attached)

2-A Flood legend on the plan that includes: (sample of flood legend provided)

1) Flood zone

2) Base flood elevation (BFE)

3) Flood Insurance Rate Map (FIRM) Panel

4) High and Low elevations of the back of all sidewalks abutting the property, identify the road

5) High and Low elevations of the crown of all roads abutting the property, identify the road

6) Proposed lowest floor elevation

7) Proposed garage floor elevation

8) Proposed lowest machinery elevation (please provide a description and location of the proposed lowest machinery)

3- Please provide a cost estimate with labor and materials.

****Please note that a BUC will be required prior to going vertical AND an FEC will be required prior to building final.*

TOTAL REVIEWS FOR ERICA VALDES: 1

ALL REVIEWS BY DUE DATE BY DEPARTMENT (08/04/2025 TO 08/09/2025)

Reviewer	Permit Number	Address	Submittal	Review	Review Status	Version	Required	Complete Date	Assigned Date	Due Date
Manuel Salazar	2024-005363	9455 Collins Ave FI 33154	Building Review (Commercial)	Building	Requires Re-submit	2*	Yes	07/24/2025	07/21/2025	08/04/2025
	<i>Comments: Need approval from electrical and structural</i>									
	2024-005390	8918 Collins Ave FI 33154	Building Review (Commercial)	Building	Pending Assignment	2*	Yes		07/21/2025	08/04/2025
TOTAL REVIEWS FOR MANUEL SALAZAR: 2										
Ulises Fernandez	2024-006723	300 Surfside Blvd FI 33154	Pool Review	Building	Approved	2*	Yes	07/18/2025	07/18/2025	08/04/2025
	2025-007343-BR	9032 Garland Ave FI 33154	Building Review (Residential)	Building	Approved	3*	Yes	07/23/2025	07/22/2025	08/05/2025
	2025-007500-BR	9148 Carlyle Ave FI 33154	Building Review (Residential)	Building	Approved	3*	Yes	07/23/2025	07/22/2025	08/05/2025
	2025-007552-BR	8942 Hawthorne Ave FI 33154	Building Review (Residential)	Building	In Review	2*	Yes		07/30/2025	08/06/2025
	2025-007733-BC	9553 Harding Ave FI 33154	Building Review (Commercial)	Building	In Review	2*	Yes		07/24/2025	08/07/2025
	2025-007754-BR	716 88Th St FI 33154	Building Review (Residential)	Building	In Review	1	Yes		07/16/2025	08/06/2025
	2025-007764-BC	9241 Collins Ave FI 33154	Building Review (Commercial)	Building	Approved	2*	Yes	07/23/2025	07/22/2025	08/05/2025
	2025-007776-BC	8877 Collins Ave 33154	Building Review (Commercial)	Building	Approved	1	Yes	07/18/2025	07/17/2025	08/07/2025
	2025-007799-BR	8836 Harding Ave FI 33154	Building Review (Residential)	Building	Approved	1	Yes	07/16/2025	07/14/2025	08/04/2025
	2025-007800-BR	1000 89Th St FI 33154	Building Review (Residential)	Building	Requires Re-submit	1	Yes	07/18/2025	07/16/2025	08/06/2025
	<i>Comments: 1. NEED MIAMI-DADE COUNTY APPROVAL. 2. PLEASE SHOW ALL SERVICE LINES ON SITE PLAN. 3. PLEASE SHOW COMPLIANCE WITH PROPERTY ADDRESS AS PER FBC R319. 4. PLEASE PROVIDE NOTE AND/OR LIST TO SHOW ALL REQUIRED SEPARATE SUBMITTALS FOR SHOP DRAWINGS AND FOR SUB-PERMITS (EX: WINDOWS/DOORS, RAILINGS, ROOFING, WATER-PROOFING, ETC.)</i>									
	2025-007803-BC	9133 Collins Ave FI 33154	Building Review (Commercial)	Building	Approved	1	Yes	07/16/2025	07/14/2025	08/04/2025
	2025-007806-BR	9032 Garland Ave FI 33154	Building Review (Residential)	Building	Requires Re-submit	1	Yes	08/03/2025	07/14/2025	08/04/2025
	<i>Comments: PLEASE PROVIDE PROPER PLANS AND DETAILS TO SHOW LOCATION AND METHOD OF CONSTRUCTION FOR BUILDING PERMIT.</i>									
	2025-007814-BC	9593 Harding Ave FI 33154	Building Review (Commercial)	Building	In Review	1	Yes		07/16/2025	08/06/2025
	2025-007825-BR	9272 Abbott Ave FI 33154	Building Review (Residential)	Building	Requires Re-submit	1	Yes	07/23/2025	07/17/2025	08/07/2025
	<i>Comments: 1. PLEASE SUBMIT FLOOR PLAN. 2. PLEASE SUBMIT WIND LOAD CALCULATIONS.</i>									
	2025-007835-BC	9511 Collins Ave FI 33154	Building Review (Commercial)	Building	In Review	1	Yes		07/17/2025	08/07/2025
	2025-007837-BR	9024 Abbott Ave FI 33154	Building Review (Residential)	Building	Approved	1	Yes	07/21/2025	07/18/2025	08/08/2025
	2025-007870	9484 Harding Ave FI 33154	Sign Review	Building	Approved	1	Yes	06/27/2025	07/23/2025	08/06/2025
	2025-007880-BR	1420 Biscaya Dr FI 33154	Building Review (Residential)	Building	In Review	1	Yes		07/25/2025	08/07/2025
	2025-007884-BR	8935 Froude Ave FI 33154	Building Review (Residential)	Building	In Review	1	Yes		07/28/2025	08/06/2025
TOTAL REVIEWS FOR ULISES FERNANDEZ: 19										
TOTAL REVIEWS FOR BUILDING: 22										

ALL REVIEWS BY DUE DATE BY DEPARTMENT (08/04/2025 TO 08/09/2025)

Reviewer	Permit Number	Address	Submittal	Review	Review Status	Version	Required	Complete Date	Assigned Date	Due Date
ELECTRICAL										
Candelario Martinez	2024-005363	9455 Collins Ave FI 33154	Building Review (Commercial)	Electrical	Requires Re-submit	2*	Yes	07/22/2025	07/21/2025	08/04/2025
		<i>Comments: Please submit the complete form/format adopted by Miami Dade County as of January 2025.</i>								
	2025-007635-Comm	9523 Harding Ave FI 33154	Electrical Trade Review	Electrical	Approved	2*	Yes	07/23/2025	07/22/2025	08/05/2025
	2025-007660-Comm	9505 Harding Ave FI 33154	Electrical Trade Review	Electrical	Requires Re-submit	2*	Yes	07/22/2025	07/21/2025	08/04/2025
		<i>Comments: description must be specific as to what type and how many low voltage devices this permit covers or plans must be submitted.</i>								
	2025-007733-BC	9553 Harding Ave FI 33154	Building Review (Commercial)	Electrical	In Review	2*	Yes		07/24/2025	08/07/2025
		<i>Comments: Please provide proof of MDC fire approval.</i>								
	2025-007799-BR	8836 Harding Ave FI 33154	Building Review (Residential)	Electrical	Requires Re-submit	1	Yes	07/15/2025	07/14/2025	08/04/2025
		<i>Comments: 1. Electrical plans must be signed and sealed by a design professional of signed by the electrical qualifier and notarized. 2. Please provide a clear scope of work and it's limitations. 3. Application says 200 amp service but plans indicate 200 amp meter with a 250 amp disconnect and panel. A load calculation will be required as well. 4. Please show the FPL letter with the transformer fault information on the plans as well as the AIC calculation and rating for all electrical equipment.</i>								
	2025-007800-BR	1000 89Th St FI 33154	Building Review (Residential)	Electrical	Approved	1	Yes	07/17/2025	07/16/2025	08/06/2025
	2025-007802-Comm	9595 Collins Ave FI 33154	Electrical Trade Review	Electrical	Requires Re-submit	1	Yes	07/15/2025	07/14/2025	08/04/2025
		<i>Comments: Signed and sealed plans required with a clear scope of work and it's limitations as well as all LED specificaitons.</i>								
	2025-007803-BC	9133 Collins Ave FI 33154	Building Review (Commercial)	Electrical	Requires Re-submit	1	Yes	07/15/2025	07/14/2025	08/04/2025
		<i>Comments: 1. Please provide a narrative for all electrical changes. 2. It appears that LED linear/strip lighting has been added to the design. Please show the following on the electrical plans: a. Location and type of driver/transformer to be used. b. Specify type of LED to be used in each location (length, wattage, etc.). c. Type and gauge/size of conductors to be used on the secondary/LV side of the drivers/transformers.</i>								
	2025-007814-BC	9593 Harding Ave FI 33154	Building Review (Commercial)	Electrical	Requires Re-submit	1	Yes	07/29/2025	07/17/2025	08/06/2025
		<i>Comments: 1. Please provide a narrative of all electrical changes and cloud changes on electrical pages. 2. Also pending proof of MDC fire department approval.</i>								
	2025-007820	9273 Byron Ave FI 33154	Electrical Trade Review	Electrical	Approved	1	Yes	07/16/2025	07/16/2025	08/06/2025
	2025-007827-Comm	9593 Harding Ave FI 33154	Electrical Trade Review	Electrical	In Review	1	Yes		07/17/2025	08/07/2025
	2025-007835-BC	9511 Collins Ave FI 33154	Building Review (Commercial)	Electrical	Requires Re-submit	1	Yes	07/31/2025	07/17/2025	08/07/2025
		<i>Comments: 1. It appears that the panel to be replaced is located in a rated smoke/fire separation. Please show on electrical page which LISTED method or product the electrical contractor shall use to protect rating around electrical panel. 2. Please show carbon monoxide detector in the locations required by the FBC.</i>								
	2025-007839-Comm	8877 Collins Ave FI 33154	Electrical Trade Review	Electrical	Approved	1	Yes	07/21/2025	07/17/2025	08/07/2025
	2025-007841	9232 Byron Ave FI 33154	Electrical Trade Review	Electrical	Approved	1	Yes	07/21/2025	07/18/2025	08/08/2025
	2025-007843-Comm	9445 Harding Ave FI 33154	Electrical Trade Review	Electrical	Approved	1	Yes	07/24/2025	07/18/2025	08/08/2025
	2025-007846	9540 Bay Dr FI 33154	Electrical Trade Review	Electrical	Approved	1	Yes	07/29/2025	07/18/2025	08/08/2025

ALL REVIEWS BY DUE DATE BY DEPARTMENT (08/04/2025 TO 08/09/2025)

Reviewer	Permit Number	Address	Submittal	Review	Review Status	Version	Required	Complete Date	Assigned Date	Due Date
	2025-007855	9559 Collins Ave FI 33154	Electrical Trade Review	Electrical	Not Required	1	Yes		07/18/2025	08/08/2025
	2025-007877	9341 Bay Dr FI 33154	Pool Review	Electrical	Not Required	1	Yes	07/31/2025	07/24/2025	08/07/2025
		<i>Comments: N/A no electrical scope included.</i>								
	MEP-2025-007743	9401 Collins Ave FI 33154	Electrical Trade Review	Electrical	Approved	1	Yes	07/17/2025	07/16/2025	08/06/2025
	MEP-2025-007804	9540 Collins Ave FI 33154	Electrical Trade Review	Electrical	Approved	1	Yes	07/15/2025	07/14/2025	08/04/2025
		<i>Comments: Renewal only approved. No new plans submitted/original approved plans will be required for all inspections.</i>								
	MEP-2025-007830	9332 Carlyle Ave FI 33154	Electrical Trade Review	Electrical	Approved	1	Yes	07/24/2025	07/17/2025	08/07/2025

TOTAL REVIEWS FOR CANDELARIO MARTINEZ: 21

TOTAL REVIEWS FOR ELECTRICAL: 21

MECHANICAL

Jan Perez	2025-007751	303 Surfside Blvd FI 33154	Mechanical Trade Review	Mechanical	Approved	1	Yes	09/19/2024	07/15/2025	08/05/2025
	2025-007800-BR	1000 89Th St FI 33154	Building Review (Residential)	Mechanical	Approved	1	Yes	07/17/2025	07/16/2025	08/06/2025
	2025-007814-BC	9593 Harding Ave FI 33154	Building Review (Commercial)	Mechanical	Approved	1	Yes	07/24/2025	07/17/2025	08/06/2025
	2025-007824	8855 Collins Ave FI 33154	Mechanical Trade Review	Mechanical	Approved	1	Yes	07/31/2025	07/17/2025	08/07/2025
	2025-007835-BC	9511 Collins Ave FI 33154	Building Review (Commercial)	Mechanical	Not Required	1	Yes		07/17/2025	08/07/2025
	2025-007855	9559 Collins Ave FI 33154	Mechanical Trade Review	Mechanical	In Review	1	Yes		07/18/2025	08/08/2025
	MEP-2025-007744	9401 Collins Ave FI 33154	Mechanical Trade Review	Mechanical	Approved	1	Yes	08/05/2025	07/16/2025	08/06/2025
	MEP-2025-007807	425 88Th St FI 33154	Mechanical Trade Review	Mechanical	Approved	1	Yes	07/17/2025	07/16/2025	08/06/2025
	MEP-2025-007826	9593 Harding Ave FI 33154	Mechanical Trade Review	Mechanical	In Review	1	Yes		07/17/2025	08/07/2025

TOTAL REVIEWS FOR JAN PEREZ: 9

TOTAL REVIEWS FOR MECHANICAL: 9

PLANNING/ZONING

Scarlet Hammons	2025-007131-BR	8818 Hawthorne Ave FI 33154	Building Review (Residential)	Planning/Zoning	Approved	4*	Yes	06/10/2025	07/25/2025	08/08/2025
	2025-007343-BR	9032 Garland Ave FI 33154	Building Review (Residential)	Planning/Zoning	Approved	3*	Yes	07/22/2025	07/22/2025	08/05/2025
	2025-007579-BC	9340 Harding Ave FI 33154	Building Review (Commercial)	Planning/Zoning	Approved	2*	Yes	07/28/2025	07/25/2025	08/08/2025
	2025-007624-BR	9349 Collins Ave FI 33154	Building Review (Residential)	Planning/Zoning	Approved	2*	Yes	07/23/2025	07/24/2025	08/07/2025
	2025-007754-BR	716 88Th St FI 33154	Building Review (Residential)	Planning/Zoning	Requires Re-submit	1	Yes	07/31/2025	07/16/2025	08/06/2025
		<i>Comments: Per sec 90-57, dock platforms are limited to a maximum of 30 feet in width dimensioned parallel to the seawall. The owner is required to provide courtesy notices to all neighbors within 300 foot radius of the property, stating that a building permit is being considered for the dock. The permit cannot be issued sooner than 15 calendar days from the time the proof of mailers are submitted to the town.</i>								
	2025-007784	9472 Harding Ave FI 33154	Sign Review	Planning/Zoning	Approved	1	Yes	07/31/2025	07/31/2025	08/08/2025
	2025-007799-BR	8836 Harding Ave FI 33154	Building Review (Residential)	Planning/Zoning	Approved	1	Yes	07/15/2025	07/14/2025	08/04/2025
	2025-007800-BR	1000 89Th St FI 33154	Building Review (Residential)	Planning/Zoning	Requires Re-submit	1	Yes	08/05/2025	07/16/2025	08/06/2025

ALL REVIEWS BY DUE DATE BY DEPARTMENT (08/04/2025 TO 08/09/2025)

Reviewer	Permit Number	Address	Submittal	Review	Review Status	Version	Required	Complete Date	Assigned Date	Due Date
<i>Comments: Architecture plans are not signed and sealed. Please sign and seal and resubmit. Need Miami Dade County stamped plans.</i>										
	2025-007852-BR	600 88 St FI 33154	Building Review (Residential)	Planning/Zoning	Approved	1	Yes	08/04/2025	07/18/2025	08/06/2025
	2025-007870	9484 Harding Ave FI 33154	Sign Review	Planning/Zoning	Approved	1	Yes	07/01/2025	07/23/2025	08/06/2025
	2025-007877	9341 Bay Dr FI 33154	Pool Review	Planning/Zoning	Requires Re-submit	1	Yes	07/30/2025	07/24/2025	08/07/2025
<i>Comments: 1. SET OF PLAN SHEETS MUST BE SIGNED AND SEALED BY PROFESSIONAL ARCHITECT/ENGINEER. 2. IF PERGOLA NEEDS REPLACEMENT, SUBMIT SEPARATE PERMIT</i>										
	2025-007884-BR	8935 Froude Ave FI 33154	Building Review (Residential)	Planning/Zoning	Approved	1	Yes	07/28/2025	07/28/2025	08/06/2025
TOTAL REVIEWS FOR SCARLET HAMMONS: 12										

TOTAL REVIEWS FOR PLANNING/ZONING: 12

PLUMBING										
Roberto Conde	2025-007101	9511 Collins Ave FI 33154	Plumbing Trade Review	Plumbing	Approved	1	Yes	07/16/2025	07/15/2025	08/05/2025
	2025-007460-BR	9455 Collins Ave FI 33154	Building Review (Residential)	Plumbing	Approved	2*	Yes	07/23/2025	07/23/2025	08/06/2025
	2025-007800-BR	1000 89Th St FI 33154	Building Review (Residential)	Plumbing	Approved	1	Yes	07/18/2025	07/16/2025	08/06/2025
	2025-007803-BC	9133 Collins Ave FI 33154	Building Review (Commercial)	Plumbing	Approved	1	Yes	07/16/2025	07/14/2025	08/04/2025
	2025-007814-BC	9593 Harding Ave FI 33154	Building Review (Commercial)	Plumbing	Approved	1	Yes	07/25/2025	07/17/2025	08/06/2025
	2025-007818	9273 Byron Ave FI 33154	Plumbing Trade Review	Plumbing	Approved	1	Yes	07/16/2025	07/16/2025	08/06/2025
	2025-007821	600 88 St FI 33154	Plumbing Trade Review	Plumbing	Approved	1	Yes	07/16/2025	07/16/2025	08/06/2025
	2025-007822	9595 Collins Ave FI 33154	Plumbing Trade Review	Plumbing	Requires Re-submit	1	Yes	07/23/2025	07/16/2025	08/06/2025
<i>Comments: PROVIDE A WATER PROOFING DETAIL FOR THE TWO FIVE FOOT TUBS THAT ARE DECK MOUNTED, SOAKING TUBS WITH NO FLANGES....CLOUD AREAS THAT ARE INCLUDED IN THE REVISION....RC</i>										
	2025-007835-BC	9511 Collins Ave FI 33154	Building Review (Commercial)	Plumbing	Approved	1	Yes	07/30/2025	07/17/2025	08/07/2025
	2025-007853	8919 Carlyle Ave FI 33154	Plumbing Trade Review	Plumbing	Approved	1	Yes	07/23/2025	07/18/2025	08/08/2025
	2025-007877	9341 Bay Dr FI 33154	Pool Review	Plumbing	Requires Re-submit	1	Yes	07/25/2025	07/24/2025	08/07/2025
<i>Comments: 1. PROVIDE SPECS FOR A VIRGINIA GRAEME BAKER POOL SAFETY ACT COMPLIANT MAIN DRAIN COVER WITH PLANS.2. PLUMBING PERMIT APPLICATION REQUIRED....R CONDE</i>										
	MEP-2025-007831	9332 Carlyle Ave FI 33154	Plumbing Trade Review	Plumbing	Approved	1	Yes	07/18/2025	07/17/2025	08/07/2025
	MEP-2025-007832	9332 Carlyle Ave FI 33154	Plumbing Trade Review	Plumbing	Approved	1	Yes	07/18/2025	07/17/2025	08/07/2025
TOTAL REVIEWS FOR ROBERTO CONDE: 13										

TOTAL REVIEWS FOR PLUMBING: 13

PUBLIC WORKS										
Andre Eugent	2025-007095-BC	9165 Collins Ave FI 33154	Building Review (Commercial)	Public Works	Approved	2*	Yes	08/05/2025	07/24/2025	08/07/2025
	2025-007800-BR	1000 89Th St FI 33154	Building Review (Residential)	Public Works	Approved	1	Yes	08/06/2025	07/16/2025	08/06/2025
	2025-007877	9341 Bay Dr FI 33154	Pool Review	Public Works	In Review	1	Yes		07/24/2025	08/07/2025

ALL REVIEWS BY DUE DATE BY DEPARTMENT (08/04/2025 TO 08/09/2025)

Reviewer	Permit Number	Address	Submittal	Review	Review Status	Version	Required	Complete Date	Assigned Date	Due Date
TOTAL REVIEWS FOR ANDRE EUGENT: 3										
TOTAL REVIEWS FOR PUBLIC WORKS: 3										
ROOF										
Ulises Fernandez	2025-007812-BC	9578 Collins Ave Fl 33154	Roof Review	Roof	Approved	1	Yes	07/18/2025	07/18/2025	08/08/2025
	2025-007828-BR	8801 Emerson Ave Fl 33154	Roof Review	Roof	Requires Re-submit	1	Yes	07/18/2025	07/17/2025	08/07/2025
Comments: 1. PLEASE PROVIDE A LEGIBLE ROOF PLAN. 2. SHOW CLEARLY LOCATION AND SIZE OF ALL PARAPET WALLS, SCUPPERS AND OFER-FLOWS. 3. PROVIDE 2- TWO ILLUSTRATIONS FOR EACH TYPE OF ROOF TYPES (SINGLE PLY AND WATER PROOFING). 4. SUBMIT MARKED U.L. TO SHOW BOTH ROOF TYPES. 5. VERIFY PARAPET (IF ANY) ON ILLUSTRATION. 5. PROVIDE COMPLIANCE WITH GENERAL LIMITATIONS PAGE OF THE NOA.										
TOTAL REVIEWS FOR ULISES FERNANDEZ: 2										
TOTAL REVIEWS FOR ROOF: 2										
STRUCTURAL										
Structural Reviewer	2024-005363	9455 Collins Ave Fl 33154	Building Review (Commercial)	Structural	In Review	2*	Yes		07/21/2025	08/04/2025
	2024-005390	8918 Collins Ave Fl 33154	Building Review (Commercial)	Structural	Requires Re-submit	2*	Yes	08/04/2025	07/21/2025	08/04/2025
	2025-007754-BR	716 88Th St Fl 33154	Building Review (Residential)	Structural	In Review	1	Yes		08/01/2025	08/06/2025
	2025-007800-BR	1000 89Th St Fl 33154	Building Review (Residential)	Structural	Requires Re-submit	1	Yes	07/31/2025	07/16/2025	08/06/2025
Comments: Please find attached link for comments: 1. https://netorgft4410985-my.sharepoint.com/:b:/g/personal/chromeeng_chromeeng_com/EbMJYiYHjUxBgZPLxkTp6ccBJwTdtaiXFL1vwMoEM8p0A?e=4Kt13q 2. https://netorgft4410985-my.sharepoint.com/:b:/g/personal/chromeeng_chromeeng_com/EXAuZbnSdUdCqkf7Ln7kgFYBgnppCDH4DuZYBU1tIL1THw?e=SylVeC										
TOTAL REVIEWS FOR STRUCTURAL REVIEWER: 4										
TOTAL REVIEWS FOR STRUCTURAL: 4										
GRAND TOTAL OF ALL REVIEWS: 86										

* This review is a resubmittal