



Department of Health
Bureau of Public Health Laboratories - Miami
 1325 N.W. 14th Avenue
 Miami, FL 33125
 Phone: 305-324-2432

County: Dade
Type of Supply: Community Water System
Type of Sample: Compliance

System Owner: TOWN OF SURFSIDE
System ID: 4131424
System Phone:
Collector/Phone: JACK A / 3056233551
Collection Addr: VARIOUS
 SURFSIDE, FL 33154

Report To:
 TOWN OF SURFSIDE
 9293 HARDING AVE
 SURFSIDE, FL 33154

Date Received: 5/24/2021 1:20:00PM
Date Analyzed: 5/24/2021 3:00:00PM
Date Reported: 5/25/2021 11:43:48PM
Sample Temp (°C): 16 On Ice
Chlorine Check: Not Detected
District:

Collect ID	Sample Point	Date Collected	Raw /Dist	Res'd CI	pH	Total Coliform	E.coli	HPC cfu/mL	Lab ID
1	8750 COLLINS AVE	5/24/2021 9:30AM	Dist	2.5	8.4	Absent	Absent		MED21001786
2	8855 COLLINS AVE	5/24/2021 9:45AM	Dist	2.5	8.4	Absent	Absent		MED21001787
3	9056 COLLINS AVE	5/24/2021 10:00AM	Dist	2.25	8.4	Absent	Absent		MED21001788
4	8826 DICKENS AVE	5/24/2021 10:15AM	Dist	2.0	8.4	Absent	Absent		MED21001789
5	1000 89 ST	5/24/2021 10:30AM	Dist	1.75	8.4	Absent	Absent		MED21001790

Lab Comments/Qualifiers:

**Water sample, as received
 considered bacteriologically
 safe for drinking purposes.
 Florida Department of Health
 Miami Dade County**

Disinfectant Residuals Avg:
Disinfectant Residuals Method:
Disinfectant Analysis Certified Operator #:
All Tests Performed in Accordance with NELAC Standards
***The Total Coliform Test includes E. coli.**
Coliform/E. Coli Method: SM 9223 B

Authorized By: Stephen White
LIMS Report #: 10627876

DEP/DOH Use Only

- Satisfactory
- Incomplete Collection Information
- Repeat Samples Required
- Replacement Samples Required

Date Reviewed by DEP/DOH: 05/26/2021
DEP/DOH Reviewing Official: *[Signature]*

Final



NELAC: E16533

Department of Health
Bureau of Public Health Laboratories - Miami

1325 N.W. 14th Avenue
Miami, FL 33125
Phone: 305-324-2432

County: Dade
Type of Supply: Community Water System
Type of Sample: Compliance

System Owner: TOWN OF SURFSIDE
System ID: 4131424
System Phone:
Collector/Phone: JACK A / 3056233551
Collection Addr: VARIOUS SURFSIDE, FL 33154

Report To: TOWN OF SURFSIDE
9293 HARDING AVE
SURFSIDE, FL 33154

Date Received: 5/24/2021 1:20:00PM
Date Analyzed: 5/24/2021 3:00:00PM
Date Reported: 5/25/2021 11:43:48PM
Sample Temp (°C): 17 On Ice
Chlorine Check: Not Detected
District:

Table with 10 columns: Collect ID, Sample Point, Date Collected, Raw /Dist, Res'd CI, pH, Total Coliform, E.coli, HPC cfu/mL, Lab ID. Contains two rows of data for sample points 9417 HARDING AVE and 9140 COLLINS AVE.

Lab Comments/Qualifiers:

Water sample, as received
considered bacteriologically
safe for drinking purposes.
Florida Department of Health
Miami Dade County

Disinfectant Residuals Avg: 2.21
Disinfectant Residuals Method:
Disinfectant Analysis Certified Operator #:

All Tests Performed in Accordance with NELAC Standards
*The Total Coliform Test includes E. coli.

Coliform/E. Coli Method: SM 9223 B

Authorized By: Stephen White
LIMS Report #: 10627877

DEP/DOH Use Only

- Satisfactory
Incomplete Collection Information
Repeat Samples Required
Replacement Samples Required

Date Reviewed by DEP/DOH: 05/26/2021
DEP/DOH Reviewing Official: [Signature]

Final