



Department of Health
Bureau of Public Health Laboratories - Miami
 1325 N.W. 14th Avenue
 Miami, FL 33125
 Phone 305-324-2432

County: Dade
Type of Supply: Community Water System
Type of Sample: Compliance

System Owner: TOWN OF SURFSIDE
System ID: 4131424
System Phone:
Collector/Phone: JACK A / 33154
Collection Addr: VARIOUS
 SURFSIDE, FL 33154


Report To:
 TOWN OF SURFSIDE
 9293 HARDING AVE
 SURFSIDE, FL 33154

Date Received: 6/17/2021 2:36:00PM
Date Analyzed: 6/17/2021 3:35:00PM
Date Reported: 6/18/2021 8:11:37PM
Sample Temp (°C): 12 On Ice
Chlorine Check: Not Detected
District:

| Collect ID | Sample Point | Date Collected | Raw /Dist | Res'd CI | pH | Total Coliform | E.coli | HPC cfu/mL | Lab ID |
|------------|------------------|-------------------|-----------|----------|-----|----------------|--------|------------|-------------|
| 6 | 9417 HARDING AVE | 6/17/2021 11:15AM | Dist | 1.5 | 8.4 | Absent | Absent | | MED21002125 |
| 7 | 9140 COLLINS AVE | 6/17/2021 11:30PM | Dist | 1.25 | 8.4 | Absent | Absent | | MED21002126 |

Lab Comments/Qualifiers:

6 (MED21002125) Sample(s) >10°C. Does not meet NELAC standards.
 7 (MED21002126) Sample(s) >10°C. Does not meet NELAC standards.



Disinfectant Residuals Avg: 1.29
 Disinfectant Residuals Method:
 Disinfectant Analysis Certified Operator #:

All Tests Performed in Accordance with NELAC Standards
 *The Total Coliform Test Includes E. coli.

Coliform/E. Coli Method: SM 9223 B

Authorized By: Stephen White
 LIMS Report #: 10688689

DEP/DOH Use Only

Satisfactory
 Incomplete Collection Information
 Repeat Samples Required
 Replacement Samples Required

Date Reviewed by DEP/DOH: 06/18/2021
 DEP/DOH Reviewing Official: [Signature]

Final



Department of Health
Bureau of Public Health Laboratories - Miami
 1325 N.W. 14th Avenue
 Miami, FL 33125
 Phone: 305-324-2432

County: Dade
Type of Supply: Community Water System
Type of Sample: Compliance

System Owner: TOWN OF SURFSIDE
System ID: 4231424
System Phone:
Collector/Phone: JACK A / 3056233551
Collection Addr: VARIOUS
 Surfside, FL 33154

Report To:
 TOWN OF SURFSIDE
 9293 HARDING AVE
 Miami Beach, FL 33154

Date Received: 6/17/2021 2:36:00PM
Date Analyzed: 6/17/2021 3:35:00PM
Date Reported: 6/18/2021 8:11:37PM
Sample Temp (°C): 11 On Ice
Chlorine Check: Not Detected
District:

| Collect ID | Sample Point | Date Collected | Raw /Dist | Res'd Cl | pH | Total Coliform | E.coli | HPC cfu/mL | Lab ID |
|------------|------------------|-------------------|-----------|----------|-----|----------------|--------|------------|-------------|
| 1 | 8750 COLLINS AVE | 6/17/2021 10:00AM | Dist | 1.75 | 8.4 | Absent | Absent | | MED21002120 |
| 2 | 8855 COLLINS AVE | 6/17/2021 10:15AM | Dist | 1.0 | 8.4 | Absent | Absent | | MED21002121 |
| 3 | 9056 COLLINS AVE | 6/17/2021 10:30AM | Dist | 1.25 | 8.4 | Absent | Absent | | MED21002122 |
| 4 | 8826 DICKENS AVE | 6/17/2021 10:45AM | Dist | 1.0 | 8.4 | Absent | Absent | | MED21002123 |
| 5 | 1000 89 ST | 6/17/2021 11:00AM | Dist | 1.25 | 8.4 | Absent | Absent | | MED21002124 |

Lab Comments/Qualifiers:

Water sample, as received
 considered bacteriologically
 safe for drinking purposes.
 Florida Department of Health
 Miami Dade County

Disinfectant Residuals Avg:
Disinfectant Residuals Method:
Disinfectant Analysis Certified Operator #:
All Tests Performed in Accordance with NELAC Standards
***The Total Coliform Test Includes E. coli.**
Coliform/E. Coli Method: SM 9223 B
Authorized By: Stephen White
LIMS Report #: 10688688

| | |
|--|-----------------------------------|
| DEP/DOH Use Only | |
| <input checked="" type="checkbox"/> | Satisfactory |
| <input type="checkbox"/> | Incomplete Collection Information |
| <input type="checkbox"/> | Repeat Samples Required |
| <input type="checkbox"/> | Replacement Samples Required |
| Date Reviewed by DEP/DOH: <u>06/18/2021</u> | |
| DEP/DOH Reviewing Official: <u>[Signature]</u> | |

Final