



NELAC: E16533

Department of Health
Bureau of Public Health Laboratories - Miami

1325 N.W. 14th Avenue

Miami, FL 33125

Phone: 305-324-2432

County: Dade
Type of Supply: Community Water System
Type of Sample: Compliance


System Owner: TOWN OF SURFSIDE
System ID: 4231424
System Phone:
Collector/Phone: JACK A / 3056233551
Collection Addr: VARIOUS
SURFSIDE, FL 33154

Report To: TOWN OF SURFSIDE
9293 HARDING AVE
SURFSIDE, FL 33154

Date Received: 7/26/2021 2:20:00PM
Date Analyzed: 7/26/2021 3:35:00PM
Date Reported: 7/27/2021 4:02:48PM
Sample Temp (°C): 14 On Ice
Chlorine Check: Not Detected
District:

Table with 10 columns: Collect ID, Sample Point, Date Collected, Raw /Dist, Res'd Cl, pH, Total Coliform, E.coli, HPC cfu/mL, Lab ID. Contains 5 rows of sample data.

Lab Comments/Qualifiers:



1. (MED21002551) Sample(s) >10°C. Does not meet NELAC standards.
2. (MED21002552) Sample(s) >10°C. Does not meet NELAC standards.

Disinfectant Residuals Avg:
Disinfectant Residuals Method:
Disinfectant Analysis Certified Operator #:

All Tests Performed in Accordance with NELAC Standards
*The Total Coliform Test includes E. coli.

Coliform/E. Coli Method: SM 9223 B

Authorized By: Stephen White
LIMS Report #: 10791618

DEP/DOH Use Only
Satisfactory
Incomplete Collection Information
Repeat Samples Required
Replacement Samples Required
Date Reviewed by DEP/DOH: 07/29/21
DEP/DOH Reviewing Official: [Signature]

Final



NELAC: E16533

Department of Health
Bureau of Public Health Laboratories - Miami

1325 N.W. 14th Avenue

Miami, FL 33125

Phone: 305-324-2432

County: Dade
Type of Supply: Community Water System
Type of Sample: Compliance

System Owner: TOWN OF SURFSIDE
System ID: 4131424
System Phone:
Collector/Phone: JACK A / 3056233551
Collection Addr: VARIOUS SURFSIDE, FL 33154

Report To: TOWN OF SURFSIDE
9293 HARDING AVE
SURFSIDE, FL 33154

Date Received: 7/26/2021 2:20:00PM
Date Analyzed: 7/26/2021 3:35:00PM
Date Reported: 7/27/2021 4:02:48PM
Sample Temp (°C): 14 On Ice
Chlorine Check: Not Detected
District:

Table with 10 columns: Collect ID, Sample Point, Date Collected, Raw /Dist, Res'd Cl, pH, Total Coliform, E.coli, HPC cfu/mL, Lab ID. Contains two rows of sample data.

Lab Comments/Qualifiers:

Water sample, as received
collected bacteriologically
safe for drinking purposes.
Florida Department of Health
Miami Dade County

Disinfectant Residuals Avg: 1.03
Disinfectant Residuals Method:
Disinfectant Analysis Certified Operator #:

All Tests Performed In Accordance with NELAC Standards
*The Total Coliform Test Includes E. coli.

Coliform/E. Coli Method: SM 9223 B

Authorized By: Stephen White
LIMS Report #: 10791619

DEP/DOH Use Only

- Satisfactory
Incomplete Collection Information
Repeat Samples Required
Replacement Samples Required

Date Reviewed by DEP/DOH: 07/29/21
DEP/DOH Reviewing Official: [Signature]

Final