



NELAC: E16533

Department of Health
Bureau of Public Health Laboratories - Miami

1325 N.W. 14th Avenue
Miami, FL 33125
Phone: 305-324-2432

County: Dade
Type of Supply: Community Water System
Type of Sample: Compliance

System Owner: TOWN OF SURFSIDE
System ID: 4131424
System Phone:
Collector/Phone: JACK A / 305 623 3551
Collection Addr: VARIOUS
SURFSIDE, FL 33154

Report To:
TOWN OF SURFSIDE
9293 HARDING AVE
SURFSIDE, FL 33154

Date Received: 2/10/2022 1:42:00PM
Date Analyzed: 2/10/2022 2:20:00PM
Date Reported: 2/11/2022 6:42:58PM
Sample Temp (°C): 9 On Ice
Chlorine Check: Not Detected
District:

Collect ID	Sample Point	Date Collected	Raw /Dist	Res'd Cl	pH	Total Coliform	E.coli	HPC cfu/mL	Lab ID
1	8750 COLLINS AVE	2/10/2022 10:00AM	Dist	3.0	8.6	Absent	Absent		MED22000535
2	8855 COLLINS AVE	2/10/2022 10:30AM	Dist	2.25	8.6	Absent	Absent		MED22000536
3	9056 COLLINS AVE	2/10/2022 10:50AM	Dist	3.0	8.6	Absent	Absent		MED22000537
4	8826 DICKENS AVE	2/10/2022 11:15AM	Dist	2.0	8.6	Absent	Absent		MED22000538
5	1000 89 ST	2/10/2022 11:45AM	Dist	2.0	8.6	Absent	Absent		MED22000539

Lab Comments/Qualifiers:

Water sample, as received considered bacteriologically safe for drinking purposes.
Florida Department of Health
Miami Dade County

Disinfectant Residuals Avg.
Disinfectant Residuals Method:
Disinfectant Analysis Certified Operator #:
All Tests Performed in Accordance with NELAC Standards
*The Total Coliform Test includes E. coli.
Coliform/E. Coli Method: SM 9223 B
Authorized By: Stephen White
LIMS Report #: 11692751

DEP/DOH Use Only

Satisfactory

Incomplete Collection Information


Repeat Samples Required

Replacement Samples Required

Date Reviewed by DEP/DOH: 02/15/2022

DEP/DOH Reviewing Official: [Signature]

Final



NELAC: E16533

**Department of Health
Bureau of Public Health Laboratories - Miami**

1325 N.W. 14th Avenue
Miami, FL 33125
Phone: 305-324-2432

County: Dade
Type of Supply: Community Water System
Type of Sample: Compliance

System Owner: TOWN OF SURFSIDE
System ID: 4131424
System Phone:
Collector/Phone: JACK A / 305 623 3551
Collection Addr: VARIOUS
SURFSIDE, FL 33154

Report To:
TOWN OF SURFSIDE
9293 HARDING AVE
SURFSIDE, FL 33154

Date Received: 2/10/2022 1:43:00PM
Date Analyzed: 2/10/2022 2:20:00PM
Date Reported: 2/11/2022 6:42:58PM
Sample Temp (°C): 9 On Ice
Chlorine Check: Not Detected
District:

Collect ID	Sample Point	Date Collected	Raw /Dist	Res'd Cl	pH	Total Coliform	E.coli	HPC cfu/mL	Lab ID
6	9417 HARDING AVE	2/10/2022 12:15PM	Dist	2.5	8.6	Absent	Absent		MED22000540
7	9140 COLLINS AVE	2/10/2022 12:30PM	Dist	2.5	8.6	Absent	Absent		MED22000541

Lab Comments/Qualifiers:

Water sample, as received considered bacteriologically safe for drinking purposes.
Florida Department of Health
Miami Dade County

Disinfectant Residuals Avg:
Disinfectant Residuals Method:
Disinfectant Analysis Certified Operator #:
All Tests Performed in Accordance with NELAC Standards
***The Total Coliform Test includes E. coli.**
Coliform/E. Coli Method: SM 9223 B
Authorized By: Stephen White
LIMS Report #: 11692752

DEP/DOH Use Only

Satisfactory

Incomplete Collection Information

Repeat Samples Required

Replacement Samples Required

Date Reviewed by DEP/DOH: 02/15/2022

DEP/DOH Reviewing Official: [Signature]

Final