DRINKING WATER BACTERIOLOGICAL SAMPLE COLLECTION AND LABORATORY REPORTING FORMAT

Miami-Dade Water & Sewer Department 6/23/2022 Collection Date: Lab Receipt Date: John E. Preston Water Quality Laboratory 6/23/2022 14:35 Lab Receipt Time: 1100 W. 2nd Ave. 6/23/2022 Setup Date: Setup Time: 15:35 Hialeah, Florida 33010 Analysis Date: 6/24/2022 Analysis Time: 14:35 Lab Certification Number E56731 Coreen Philip, (786) 552-4738 Sample Acceptance Criteria Report Number: 220624081752 Sub-Contract Lab ID X on ice not on ice Sample Preservation Analysis Requested: (please X all that applies) X Not Detected Disinfection Check MMO/MUG HPC X Standard Coliform Test Other This sample does not meet the following NELAC requirem System Name: Town of Surfside PWS I.D. 9293 Harding Ave. System Address: City: Surfside System or Owner's Phone #: Fax#: Collector: Assad Jamil Collector's Phone #: 786-552-4738 Assad Jamil Analyst: X Community Water System Well Noncommunity Water System Type of Supply: Nontransient Noncommunity Water System Reason for Sampling (X only one) X Routine Compliance Main Clearance Repeat Main Break Wells Replacement Other 6/23/2022 **Collection Date:** Sample Point Disinfectant Total LIMS Sample (Location or Specific Address) Collection Sample Res'd (mg/L) Non Coliform Confirm Data Assigned Number Time Type1 Free Total ρН Coliform SM9222B E. Coli Qualifier Number 1 1000 89 St. 11:04 D 1.4 A AR20112 2 8826 Dickens Ave. 11:17 D 2.2 A AR20113 3 8750 Collins Ave. 11:31 D 3.2 Α AR20114 4 9417 Harding Ave. 11:48 D 1.8 Α AR20115 5 8855 Collins Ave. 12:03 D 1.2 Α AR20116 6 9056 Collins Ave. 12:19 D 2.6 A AR20117 7 9140 Collins Ave. D 12:33 2.4 A AR20118 Average of disinfectant residuals for routine and repeated samples. (Complete for 2.11 Defined in Florida Adminitrative Dode Rule 62-160. Table 1 community and nontransient non-community systems serving populations up to and including 4900. Do no include raw or plant samples in the average.) Results relate only to items tested for the sampe received in the JEPWQL. This report shall not be reproduced except in full, without the written approval of the Disinfectant Residdal Analysis Method: X **DPD** Colorimetric Other JEPWOL Person performing analysis is (Please see instructions on reverse): All tests are performed in accordance with NELAC standards. A Certified Operator # Employed by a Certified Lab Date PWS notified by lab of positive results: Supervised by a Certified Operator # Date State notified by lab of positive results Reviewing Offical: Name and Mailing Address of Person To Receive Report Title: Chemist 3 Dr. Samir Elmir, P.E. DEP/DOH USE ONLY Satisfactory Drinking Water Program Administrator Incomplete Collection Information State of Florida Repeat Samples Required Department of Health Replacement Samples Required 1725 N.W. 167 Street, Suite 119 Date Reviewed by DEP/DOH: Miami, Florida 33056 DEP/DOH Reviewing Official: DEP Sample Type Codes: D = Distribution (Routine Compliance); C = Repeat or Check; R = Raw; N = Entry of Distribution; P = Plant Tap; S = Special (Clearance Analysis Methods: MF = SM9222B & D; MMO/MUG = SM9223B; HPC = SM9215B; pH = SM45000-H+; Color = SM2120B; Turbidity = SM2130B

PAGE 1 OF 1

(62-550.730 Reporting Formal - Effective 01/95, Revised 01/04

Result: A = Total coliforms are absent; P = Total coliforms are present; C = confluent growth; TNTC = too numberout to count