

NELAC E16533

Department of Health
Bureau of Public Health Laboratories - Miami

1325 N.W. 14th Avenue

Miami, FL 33125

Phone: 305-324-2432

Provisional EPA Certification

County: Dade
Type of Supply: Community Water System
Type of Sample: Compliance

System Owner: TOWN OF SURFSIDE
System ID: 4131424
System Phone:
Collector/Phone: JACK A / 305 623 3551
Collection Addr: VARIOUS
 Surfside, FL 33154

Report To:
 TOWN OF SURFSIDE
 9293 HARDING AVE
 Surfside, FL 33154

Date Received: 7/20/2023 2:19:00PM
Date Analyzed: 7/20/2023 4:10:00PM
Date Reported: 7/21/2023 6:12:37PM
Sample Temp (°C): 9 On Ice
Chlorine Check: Not Detected
District:

Collect ID	Sample Point	Date Collected	Raw /Dist	Res'd Cl	pH	Total Coliform	E.coli	HPC cfu/mL	Lab ID
1	8750 COLLINS AVE	7/20/2023 9:45AM	Dist	2.5	8.6	Absent	Absent		MED23002846
2	8855 COLLINS AVE	7/20/2023 10:05AM	Dist	2.5	8.6	Absent	Absent		MED23002847
3	9056 COLLINS AVE	7/20/2023 10:25AM	Dist	2.5	8.6	Absent	Absent		MED23002848
4	8826 DICKENS AVE	7/20/2023 10:45AM	Dist	2.0	8.6	Absent	Absent		MED23002849
5	1000 89 ST	7/20/2023 11:05AM	Dist	2.0	8.6	Absent	Absent		MED23002850

Lab Comments/Qualifiers:

Water sample, as received considered bacteriologically safe for drinking purposes.
 Florida Department of Health
 Miami Dade County


Disinfectant Residuals Avg:
Disinfectant Residuals Method:
Disinfectant Analysis Certified Operator #:
All Tests Performed in Accordance with NELAC Standards
 *The Total Coliform Test includes E. coli.
Coliform/E. Coli Method: SM 9223 B
Authorized By: Dr. Xihui Newman
LIMS Report #: 12746622

DEP/DOH Use Only

Satisfactory
 Incomplete Collection Information
 Repeat Samples Required
 Replacement Samples Required

Date Reviewed by DEP/DOH: 07.21.2023
 DEP/DOH Reviewing Official: _____

Final



NELAC: E16533

Department of Health
Bureau of Public Health Laboratories - Miami

1325 N.W. 14th Avenue
 Miami, FL 33125

Phone: 305-324-2432

Provisional EPA Certification

County: Dade
Type of Supply: Community Water System
Type of Sample: Compliance

System Owner: TOWN OF SURFSIDE
System ID: 4131424
System Phone:
Collector/Phone: JACK A / 305 623 3551
Collection Addr: VARIOUS
 Surfside, FL 33154

Report To:
 TOWN OF SURFSIDE
 9293 HARDING AVE
 Surfside, FL 33154

Date Received: 7/20/2023 2:19:00PM
Date Analyzed: 7/20/2023 4:10:00PM
Date Reported: 7/21/2023 6:12:37PM
Sample Temp (°C): 12 On Ice
Chlorine Check: Not Detected
District:

Collect ID	Sample Point	Date Collected	Raw /Dist	Res'd Cl	pH	Total Coliform	E.coli	HPC cfu/mL	Lab ID
6	9417 HARDING AVE	7/20/2023 11:25AM	Dist	2.5	8.6	Absent	Absent		MED23002851
7	9140 COLLINS AVE	7/20/2023 11:40AM	Dist	2.5	8.6	Absent	Absent		MED23002852

Lab Comments/Qualifiers:


Water sample, as received considered bacteriologically safe for drinking purposes.
 Florida Department of Health
 Miami Dade County

2.36 mg/l

Disinfectant Residuals Avg:
Disinfectant Residuals Method:
Disinfectant Analysis Certified Operator #:
All Tests Performed in Accordance with NELAC Standards
 *The Total Coliform Test includes E. coli.
Coliform/E. Coli Method: SM 9223 B
Authorized By: Dr. Xihui Newman
LIMS Report #: 12746625

DEP/DOH Use Only

Satisfactory
 Incomplete Collection Information
 Repeat Samples Required
 Replacement Samples Required

Date Reviewed by DEP/DOH: 07/21/2023
 DEP/DOH Reviewing Official: 

Final