



NELAC: E16533

Department of Health
Bureau of Public Health Laboratories - Miami

1325 N.W. 14th Avenue
 Miami, FL 33125

Phone: 305-324-2432

Provisional EPA Certification

County: Dade
Type of Supply: Community Water System
Type of Sample: Compliance

System Owner: TOWN OF SURFSIDE
System ID: 4131424
System Phone:
Collector/Phone: JACK A / 305 623 3551
Collection Addr: VARIOUS
 Surfside, FL 33154

Report To:
 TOWN OF SURFSIDE
 9293 HARDING AVE
 Surfside, FL 33154

Date Received: 11/20/2023 2:41:00PM
Date Analyzed: 11/20/2023 3:25:00PM
Date Reported: 11/21/2023 4:59:27PM
Sample Temp (°C): 11 On Ice
Chlorine Check: Not Detected
District:

| Collect ID | Sample Point | Date Collected | Raw /Dist | Res'd Cl | pH | Total Coliform | E.coli | HPC cfu/mL | Lab ID |
|------------|------------------|--------------------|-----------|----------|-----|----------------|--------|------------|-------------|
| 1 | 8750 COLLINS AVE | 11/20/2023 11:00AM | Dist | 2.25 | 8.6 | Absent | Absent | | MED23004479 |
| 2 | 8855 COLLINS AVE | 11/20/2023 11:20AM | Dist | 2.5 | 8.6 | Absent | Absent | | MED23004480 |
| 3 | 9056 COLLINS AVE | 11/20/2023 11:40AM | Dist | 2.0 | 8.6 | Absent | Absent | | MED23004481 |
| 4 | 8826 DICKENS AVE | 11/20/2023 12:00PM | Dist | 2.0 | 8.6 | Absent | Absent | | MED23004482 |
| 5 | 1000 89 ST | 11/20/2023 12:20PM | Dist | 2.0 | 8.6 | Absent | Absent | | MED23004483 |

Lab Comments/Qualifiers:

Water sample, as received considered bacteriologically safe for drinking purposes.
 Florida Department of Health
 Miami Dade County

Disinfectant Residuals Avg:
Disinfectant Residuals Method:
Disinfectant Analysis Certified Operator #:
All Tests Performed in Accordance with NELAC Standards
***The Total Coliform Test includes E. coli.**
Coliform/E. Coli Method: SM 9223 B
Authorized By: Dr. Xihui Newman
LIMS Report #: 13024477

DEP/DOH Use Only

Satisfactory
 Incomplete Collection Information
 Repeat Samples Required
 Replacement Samples Required

Date Reviewed by DEP/DOH: 11-21-2023
 DEP/DOH Reviewing Official: _____

Final



NELAC: E16533

Department of Health
Bureau of Public Health Laboratories - Miami

1325 N.W. 14th Avenue
 Miami, FL 33125

Phone: 305-324-2432

Provisional EPA Certification

County: Dade
Type of Supply: Community Water System
Type of Sample: Compliance

System Owner: TOWN OF SURFSIDE
System ID: 4131424
System Phone:
Collector/Phone: JACK A / 305 623 3551
Collection Addr: VARIOUS
 Surfside, FL 33154

Report To:
 TOWN OF SURFSIDE
 9293 HARDING AVE
 Surfside, FL 33154

Date Received: 11/20/2023 2:41:00PM
Date Analyzed: 11/20/2023 3:25:00PM
Date Reported: 11/21/2023 4:59:27PM
Sample Temp (°C): 11 On Ice
Chlorine Check: Not Detected
District:

| Collect ID | Sample Point | Date Collected | Time | Raw /Dist | Res'd Cl | pH | Total Coliform | E.coli | HPC cfu/mL | Lab ID |
|------------|------------------|----------------|---------|-----------|----------|-----|----------------|--------|------------|-------------|
| 6 | 9417 HARDING AVE | 11/20/2023 | 12:40PM | Dist | 2.25 | 8.6 | Absent | Absent | | MED23004484 |
| 7 | 9140 COLLINS AVE | 11/20/2023 | 1:00PM | Dist | 2.5 | 8.6 | Absent | Absent | | MED23004485 |

Lab Comments/Qualifiers:

Water sample, as received considered bacteriologically safe for drinking purposes.
 Florida Department of Health
 Miami Dade County

2.21 mg/L.

Disinfectant Residuals Avg:
Disinfectant Residuals Method:
Disinfectant Analysis Certified Operator #:
All Tests Performed in Accordance with NELAC Standards
***The Total Coliform Test includes E. coli.**
Coliform/E. Coli Method: SM 9223 B
Authorized By: Dr. Xihui Newman
LIMS Report #: 13024478

DEP/DOH Use Only

Satisfactory
 Incomplete Collection Information
 Repeat Samples Required
 Replacement Samples Required

Date Reviewed by DEP/DOH: 11/21/2023
 DEP/DOH Reviewing Official:

Final