

NELAC: E16533

**Department of Health
Bureau of Public Health Laboratories - Miami**

1325 N.W. 14th Avenue
Miami, FL 33125

Phone: 305-324-2432

Provisional EPA Certification

County: Dade
Type of Supply: Community Water System
Type of Sample: Compliance

System Owner: TOWN OF SURFSIDE
System ID: 4131424
System Phone:
Collector/Phone: JACK A / 305 623 3551
Collection Addr: VARIOUS
Surfside, FL 33154

Report To:
TOWN OF SURFSIDE
9293 HARDING AVE
Surfside, FL 33154


Date Received: 9/13/2023 2:42:00PM
Date Analyzed: 9/13/2023 3:00:00PM
Date Reported: 9/14/2023 11:37:51PM
Sample Temp (°C): 10 On Ice
Chlorine Check: Not Detected
District:

Collect ID	Sample Point	Date Collected	Raw /Dist	Res'd Cl	pH	Total Coliform	E.coli	HPC cfu/mL	Lab ID
1	8750 COLLINS AVE	9/13/2023 10:30AM	Dist	2.0	8.6	Absent	Absent		MED23003651
2	8855 COLLINS AVE	9/13/2023 10:50AM	Dist	2.25	8.6	Absent	Absent		MED23003652
3	9056 COLLINS AVE	9/13/2023 11:10AM	Dist	1.75	8.6	Absent	Absent		MED23003653
4	8826 DICKENS AVE	9/13/2023 11:30AM	Dist	1.5	8.6	Absent	Absent		MED23003654
5	1000 89 ST	9/13/2023 11:55AM	Dist	1.5	8.6	Absent	Absent		MED23003655


Lab Comments/Qualifiers:

Water sample, as received
considered bacteriologically
safe for drinking purposes.
Florida Department of Health
Miami Dade County

Disinfectant Residuals Avg:
Disinfectant Residuals Method:
Disinfectant Analysis Certified Operator #:
All Tests Performed in Accordance with NELAC Standards
***The Total Coliform Test includes E. coli.**
Coliform/E. Coll Method: SM 9223 B
Authorized By: Dr. Xihui Newman
LIMS Report #: 12874119

DEP/DOH Use Only	
<input checked="" type="checkbox"/> Satisfactory	
<input type="checkbox"/> Incomplete Collection Information	
<input type="checkbox"/> Repeat Samples Required	
<input type="checkbox"/> Replacement Samples Required	
Date Reviewed by DEP/DOH:	09.15.2023
DEP/DOH Reviewing Official:	

Final



NELAC: E16533

Department of Health
Bureau of Public Health Laboratories - Miami

1325 N.W. 14th Avenue
Miami, FL 33125

Phone: 305-324-2432

Provisional EPA Certification

County: Dade
Type of Supply: Community Water System
Type of Sample: Compliance

System Owner: TOWN OF SURFSIDE
System ID: 4131424
System Phone:
Collector/Phone: JACK A / 305 623 3551
Collection Addr: VARIOUS
Surfside, FL 33154

Report To:
TOWN OF SURFSIDE
9293 HARDING AVE
Surfside, FL 33154

Date Received: 9/13/2023 2:43:00PM
Date Analyzed: 9/13/2023 3:00:00PM
Date Reported: 9/14/2023 11:37:52PM
Sample Temp (°C): 12 On Ice
Chlorine Check: Not Detected
District:

Collect ID	Sample Point	Date Collected	Raw /Dist	Res'd Cl	pH	Total Coliform	E.coli	HPC cfu/mL	Lab ID
6	9417 HARDING AVE	9/13/2023 12:20PM	Dist	2.0	8.6	Absent	Absent		MED23003656
7	9140 COLLINS AVE	9/13/2023 12:40PM	Dist	1.75	8.6	Absent	Absent		MED23003657

Lab Comments/Qualifiers:

Water sample, as received considered bacteriologically safe for drinking purposes.
Florida Department of Health
Miami Dade County

Disinfectant Residuals Avg: *1.82 ug/l*
Disinfectant Residuals Method:
Disinfectant Analysis Certified Operator #:
All Tests Performed in Accordance with NELAC Standards
*The Total Coliform Test includes E. coli.
Coliform/E. Coll Method: SM 9223 B
Authorized By: Dr. Xihui Newman
LIMS Report #: 12874120

DEP/DOH Use Only

Satisfactory
 Incomplete Collection Information
 Repeat Samples Required
 Replacement Samples Required

Date Reviewed by DEP/DOH: *09/15/2023*
 DEP/DOH Reviewing Official: *[Signature]*

Final